

Er.K.G.MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG.NO M-111304/0], PPE (PANEL.REG NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved valuer/Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

CERTIFICATE OF STRUCTURAL SOUNDNESS STATEMENT ACCOMPANYING FORM-A

Date: 01.11.2025

1. Door No. of the Building : AKSHARDHAM CENTRAL SCHOOL
T.S.NO. 2/8 pt,3/1A2 pt, 3/1A3
Ward B, Block 29
2. Location (Street Name, Ward No., Name of the Place, i.e. Corporation / Municipality/Panchayat/Panchayat Union/Township/Cantonment, etc) : Panampattu,
Villupuram Municipal Limit,
Villupuram Taluk & District
3. Year of construction : 2019
4. Approximate cost of construction as per current rates : Rs.15 Crores (Rupees Fifteen Crores only)
5. Purpose for which the building is being used or proposed to be used : Educational purpose
6. Purpose for which the building hither been used : Educational purpose
7. Details of construction of the building
 - a) Foundation : Isolated column footing / Strip Footing
 - b) Basement : Frames, Tie Beam & Brick Masonry walls
 - c) Superstructure : Frames & Brick Masonry
 - d) Floor & Roof : Tiled floor & RCC Roof
 - e) Area of the Building
 - Ground Floor Area : 3313.24 Sq.mt
 - First Floor Area : 3134.00 Sq.mt
 - Second Floor Area : 3134.00 Sq.mt
 - Head Room : 164.32 Sq.mt
 - Total Buildup Area : 9745.56 Sq.mt
 - f) Land Area / Site Area : 14420 Sq.mt (As per Plan enclosed)


Er. K. G. MANIVACHAKAM
B.E., M.I.E., F.I.V. C.Engg.
Certifying Engineer (Class-IA) for Issuance
of Structural Soundness Certificate
for Public Buildings under The
TN Public Buildings Licensing Act, 1965.
D.No: 3/201, First Cross Street, Friends Nagar,
Opp: District Employment Office, Semmanduram,
Cuddalore - 607 001. Mobile: 9842332323.

ADDRESS:

3/201, 1ST cross street, Friends Nagar, Cuddalore-607001. (TN) Off: 91-4142-290207 Mobile: 91-98423-32323
Email:kgmaniv@gmail.com



Er. K. G. MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG.NO M-111304/D], PPE (PANEL.REG NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved valuer/Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

8. Period for which license is required : From 01.12.2025 to 30.11.2028 (3 Years)
9. Number of persons to be accommodated : 1800 students
10. Applicant : M/s MAHALAKSHMI EDUCATIONAL TRUST

"Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to opinion a fresh license in case any addition or alteration is made to the existing building. I also undertake to obtain a fresh license if the purpose for which the license was granted fit the use of the building or a portion originally changed or altered subsequently."

Date: 01.11.2025

Signature of the owner of the Building

Date: 01.11.2025

Signature of the Registered Engineer.

Er. K. G. MANIVACHAKAM

B.E., M.I.E., F.I.V. C.Engg.

Certifying Engineer (Class-IA) for Issuance of Structural Soundness Certificate for Public Buildings under The TN Public Buildings Licensing Act, 1965.
D.No: 3/201, First Cross Street, Friends Nagar,
Opp: District Employment Office, Semmandalam,
Cuddalore - 607 001. Mobile: 9842332333.

ADDRESS:

3/201, 1st cross street, Friends Nagar, Cuddalore-607001. (TN) Off: 91-4142-290207 Mobile: 91-98423-32323
Email:kgmanlv@gmail.com



Er.K.G.MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG.NO M-111304/0], PPE (PANEL.REG NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved valuer/Civil Engineer,
Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

FORM-B

(Form of certificate of structural soundness under sub section (4) of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rule 1966)

I certify that I have inspected the building, mentioned in the statement and furnish below its salient technical features:-

I. FOUNDATION:

1. Depth below ground level : 2.5 M
2. Nature of soil not with at foundation level : Clay and Sand mixed
3. Pressure at foundation : 10 T/M²
4. Probable safe bearing capacity of the soil met with at foundation : 16 T/M²

II. SUPER STRUCTURE:

1. Maximum stress in the most critical section of Masonry & concrete : Does not arise (Framed Structure)
2. Nature of Masonry and concrete & it's safe Permissible stress : Does not arise (Framed Structure)

The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 878 (Latest Version) and other relevant Indian standards code of practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A license may be granted for the period from 01.12.2025 to 30.11.2028 (3 Years)

Date: 01.11.2025

Er.K.G.MANIVACHAKAM
B.E., M.I.E., F.I.V.
Certifying Engineer (Class-IA) for Issuance
of Structural Soundness Certificate
for Public Buildings under The
TN Public Buildings Licensing Act, 1965.
D.No: 3/201, First Cross Street, Friends Nagar,
Opp: District Employment Office, Semmandalam,
Cuddalore - 607 001. Mobile: 9842332323.

Signature of the Registered Engineer

ADDRESS:

3/201, 1ST cross street, Friends Nagar, Cuddalore-607001. (TN) Off: 91-4142-290207 Mobile: 91-98423-32323
Email:kgmaniv@gmail.com



Er.K.G.MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG.NO M-111304/0], PPE (PANEL.REG NO M2/80777/96), I.V-REG.NO F-10285

Chartered Engineer (India), Approved valuer/Civil Engineer,
Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

FORM-C

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

1. Location of the Building (Door No, Street Name & Name of the Place) : AKSHARDHAM CENTRAL SCHOOL
T.S.NO. 2/8 pt,3/1A2 pt, 3/1A3
Ward B, Block 29
Panampattu,
Villupuram Municipal Limit,
Villupuram Taluk & District
2. Age of the Building : 6 years
3. Number of Storey : GF, FF & SF (G+2)
4. Short description of structures, Steel RCC : RCC framed structure
framed or load bearing masonry
5. Purpose for which the building is certified for use : Educational purpose
6. The period for which the building will be structurally sound : From 01.12.2025 to 30.11.2028 (3 Years)
7. Number of persons to be accommodated : 1800 students
8. Remarks : Certified that the buildings are structurally sound.

Date: 01.11.2025


Signature of the Registered Engineer

Er. K.G. MANIVACHAKAM

B.E., M.I.E., F.I.V. C.Engg.
Certifying Engineer (Class-1A) for Issuance
of Structural Soundness Certificate
for Public Buildings under The
TN Public Buildings Licensing Act, 1965.
D.No: 3/201, First Cross Street, Friends Nagar,
Opp: District Employment Office, Semmandalam,
Cuddalore - 607 001. Mobile: 9842332323.

ADDRESS:

3/201, 1st cross street, Friends Nagar, Cuddalore-607001. (TN) Off: 91-4142-290207 Mobile: 91-98423-32323
Email: kgmaniv@gmail.com



Er.K.G.MANIVACHAKAM B.E., M.I.E., F.I.V

IEI [REG.NO M-111304/0], PPE (PANEL.REG NO M2/80777/96), I V-REG.NO F-10285

Chartered Engineer (India), Approved valuer/Civil Engineer,

Class 1A Registered engineer, competent person to release structural soundness certificate for public buildings

FORM-E

(Form of Report to be made to the competent Authority by Inspecting authorities or officers appointed under other acts under Sec. 28 of the Madras Public Buildings (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 7 of the Madras Public Buildings (Licensing) Rules 1966 Act.)

1. Name and Designation of the inspecting authority or officer appointed by or having jurisdiction under any other act or law : Er. K.G. MANIVACHAKAM, B.E, MIE, FIV. CHARTERED ENGINEER (INDIA), Class 1-A Panel Registered Engineer.
2. Location of the Building (Door No, Street Name & Name of the Place) : AKSHARDHAM CENTRAL SCHOOL T.S.NO. 2/8 pt,3/1A2 pt, 3/1A3 Ward B, Block 29 Panampattu, Villupuram Municipal Limit, Villupuram Taluk & District
3. Date of Inspection : 31.10.2025
4. Purpose for which the building is used : Educational Purpose
5. Nature of defects noticed : No Defects found
6. Suggestion for rectifying defects : Does not arise
7. If in a dangerous condition immediate steps recommended to be taken. : Does not arise

Date:01.11.2025

Er. K.G. MANIVACHAKAM

B.E., M.I.E., F.I.V. C.Engg.,
Certifying Engineer (Class-IA) for Issuance
of Structural Soundness Certificate
for Public Buildings under The
TN Public Buildings Licensing Act, 1965.
D.No: 3/201, First Cross Street, Friends Nagar,
Opp: District Employment Office, Semmandalam,
Cuddalore - 607 001. Mobile: 9842332323.

Signature of the Inspecting Authority /
officer appointed / having Jurisdiction.

ADDRESS:

3/201, 1st cross street, Friends Nagar, Cuddalore-607001. (TN) Off: 91-4142-290207 Mobile: 91-98423-32323
Email:kgmanlv@gmail.com

5

